



# SUBMITTAL INFORMATION

## Corporation Stop Replacement Piece - (F60-6-x style)



### AWWA/CC TAPER THREAD INLET BY PACK JOINT FOR POLYETHYLENE PIPE (PEP) OUTLET



| DESCRIPTION |             | LENGTH   | APPROX. WT. LBS | PART NUMBER | ✓ SUBMITTED ITEM(S) |
|-------------|-------------|----------|-----------------|-------------|---------------------|
| INLET SIZE  | OUTLET SIZE |          |                 |             |                     |
| 3/4"        | 3/4"        | 2-5/8"   | .8              | F60-6-3     |                     |
| 1"          | 1"          | 2-13/16" | 1.3             | F60-6-4     |                     |

**Note:** Ford recommends using insert stiffeners with plastic pipe or tubing.

## FEATURES

- All brass conforms to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- Body design provides larger, more rugged wrench flats for proper installation.
- Replaces F1001 Corporation Stops and FB1001 Ballcorps.

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



### The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

<http://www.fordmeterbox.com>

07/28/04

Submitted By: