


SUBMITTAL INFORMATION

Brass Saddles For C900 PVC - (S902-xxx style)




BRASS SADDLES WITH AWWA TAPS FOR C900 PVC PIPE

Brass alloy body and strap,
meeting ASTM B-62, ASTM B-584
and AWWA C800

EPDM Rubber O-Ring gasket

Silicon Bronze Bolts



2-Piece Bolted Design

PVC PIPE SIZE	ACTUAL O.D.	TAP SIZE	APPROX. Wt. LBS.	CATALOG NUMBER	✓ SUBMITTED ITEM(s)
4"	4.80	1/2"	2.8	S902-401	
		3/4"	2.9	S902-403	
		1"	2.8	S902-404	
		1-1/2"	-	S902-406	
		2"	-	S902-407	
6"	6.90	1/2"	4.5	S902-601	
		3/4"	4.6	S902-603	
		1"	4.5	S902-604	
		1-1/2"	-	S902-606	
		2"	-	S902-607	
8"	9.05	1/2"	5.3	S902-801	
		3/4"	5.4	S902-803	
		1"	5.3	S902-804	
		1-1/2"	-	S902-806	
		2"	-	S902-807	

FEATURES

- All brass conforms to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- These saddles conform to the design and sizing requirements held by the Uni-Bell Handbook and the AWWA manual M23 for use on PVC pipe.
- O-Ring gasket is EPDM rubber, ASTM D2000.

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

<http://www.fordmeterbox.com>

06/12/07

Submitted By: