



SUBMITTAL INFORMATION

90 Series Coppersetter - (VBHC93-xxW-81-33xx style)




ANGLE BALL VALVE BY ANGLE DUAL CARTRIDGE CHECK VALVE (3/4" METER)

MALE IRON PIPE UNION SWIVEL INLET BY DOUBLE PURPOSE UNION SWIVEL OUTLET



Options



Coppersetter Part Number

HEIGHT (INCHES)	APPROX. WT. LBS.	CATALOG NUMBER	✓ SUBMITTED ITEM(S)
15	7.5	VBHC93-15W-81-33xx	
18	8.1	VBHC93-18W-81-33xx	
21	8.4	VBHC93-21W-81-33xx	
24	8.7	VBHC93-24W-81-33xx	
27	-	VBHC93-27W-81-33xx	
30	-	VBHC93-30W-81-33xx	
33	-	VBHC93-33W-81-33xx	
36	-	VBHC93-36W-81-33xx	

xx = Add Option Code to catalog number if required. See tables below.

Option Codes for 90 Series Coppersetters

OPTION	EXTENSION TO CATALOG NUMBER
Brace Eye	Add "E" to Cat. No.
Bolted Clamp Construction	Add "C" to Cat. No.
15" outlet tube extension	Add "A" to Cat. No.
15" outlet tube extension & brace eye	Add "H" to Cat. No.
15" outlet tube extension & bolted clamp	Add "F" to Cat. No.
18" outlet tube extension	Add "B" to Cat. No.
18" outlet tube extension & brace eye	Add "K" to Cat. No.
18" outlet tube extension & bolted clamp	Add "J" to Cat. No.

Add extension to catalog number. Example: VBHC93-21W-81-33B

Inlet Tube Options for 90 Series Coppersetters

OPTION	COPPERSETTER SIZE	INLET TUBE OPTION CODE
15" inlet tube extension	3/4"	Add "P" to Cat. No.
18" inlet tube extension	3/4"	Add "S" to Cat. No.
Vertical inlet extension	3/4"	Add "Z" to Cat. No.

Place catalog inlet tube code to the left of any other extension option from the top option table. Example: VBHC93-21W-81-33SK

Service Line Size

INLET	OUTLET
3/4" M.I.P. Union Swivel	3/4" D.P. Swivel

FEATURES

- All brass conforms to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- Saddle Nuts hold the meter in place for tightening.
- Brace Eye is optional for all 90 Series Coppersetters with standard solder clamp.
- Service line extensions and bolted clamp construction are optional on 90 Series.
- All Ford Setters are assembled with lead-free solder.

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

<http://www.fordmeterbox.com>

06/23/06

Submitted By: