


Repair Kit for Ford Dual Cartridge Check Valves 3/4" & 1" HHCA Angle Style 3/4" & 1" HHC Straight Style

Catalog Numbers:

HHCRK-3 for 3/4", **HHCRK-4** for 1"



Item	Description	Quantity
1	HHCA Access Cap O-Ring (Angle Style)	1
2	HHC Flat Gasket (Straight Style)	1
3	Check Valve Assembly	2

1. Remove existing components from check valve. Also remove any accumulations, wear or damage preventing proper check valve function.
2. Lubricate the cartridge check O-rings with an FDA approved silicone grease.
3. Insert cartridges into the valve body so that the checks open in the direction of normal water flow.
4. Replace HHCA End Cap O-ring — or —
5. Replace HHC Swivel Nut flat gasket.
6. Discard unused O-ring or gasket.
7. Check for leaks.



The Ford Meter Box Company, Inc.


775 Manchester Avenue, P.O. Box 443,
Wabash, Indiana 46992-0443 USA
Phone: 260-563-3171 • FAX: 800-826-3487
Overseas FAX: 260-563-0167
<http://www.fordmeterbox.com>

08/12

Repair Kit for Ford Dual Cartridge Check Valves 3/4" & 1" HHCA Angle Style 3/4" & 1" HHC Straight Style

Catalog Numbers:

HHCRK-3 for 3/4", **HHCRK-4** for 1"



Item	Description	Quantity
1	HHCA Access Cap O-Ring (Angle Style)	1
2	HHC Flat Gasket (Straight Style)	1
3	Check Valve Assembly	2

1. Remove existing components from check valve. Also remove any accumulations, wear or damage preventing proper check valve function.
2. Lubricate the cartridge check O-rings with an FDA approved silicone grease.
3. Insert cartridges into the valve body so that the checks open in the direction of normal water flow.
4. Replace HHCA End Cap O-ring — or —
5. Replace HHC Swivel Nut flat gasket.
6. Discard unused O-ring or gasket.
7. Check for leaks.



The Ford Meter Box Company, Inc.

775 Manchester Avenue, P.O. Box 443,
Wabash, Indiana 46992-0443 USA
Phone: 260-563-3171 • FAX: 800-826-3487
Overseas FAX: 260-563-0167
<http://www.fordmeterbox.com>

#020276

08/12

#020276